



# Florida Department of Environmental Protection

Bob Martinez Center  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Rick Scott  
Governor

Carlos Lopez-Cantera  
Lt. Governor

Jonathan P. Steverson  
Secretary

## PERMITTEE:

Water Recovery, LLC  
1819 Albert Street  
Jacksonville, Florida 32202

I.D. Number: FLR 000 069 062  
Permit Number: 79677-HO-012  
Date of Issue: January 29, 2016  
Expiration Date: October 11, 2020  
County: Duval  
Lat/Long: 30°19' 45" N/81° 37' 25" W

Attention:  
Mr. Gregory Reynolds,  
Vice President and General Manager

Project: Used Oil Processing Facility

This permit is issued under the provisions of Chapter 403 of Florida Statutes (F.S.), Chapters 62-4, 62-160, 62-701, 62-710, 62-730, 62-740 and 62-762 of Florida Administrative Code (F.A.C.), and 40 Code of Federal Regulations (CFR) Part 279. The above named Permittee is hereby authorized to perform the work or operate the facility shown on the application dated August 12, 2015, October 09, 2015, November 02, 2015 and approved drawing(s), plans, and other documents attached hereto or on file with the Department and made a part hereto and specifically described as follows:

To operate a Used Oil Processing Facility consisting of a tank storage and processing area and a container storage area, hereinafter referred to as "Facility" (Attachment A).

The tank storage and processing area consists of ten (10) aboveground storage tanks and a heater unit, which may be used to store or process used oil, oily water, petroleum contact water (PCW), sludges/solids, and Industrial Wastewater. Tanks 1-P, 2-P, 3-P, 4-P, 5-P, 6-P, 7-P, 8-P, 9-P, 10-P and the Heater are located within secondary containment on the north side of the facility. Tanks 1-P, 2-P and 3-P have a capacity of 23,232 gallons each. Tank 4-P has a capacity of 21,445 gallons; Tank 5-P has a capacity of 20,778 gallons; Tank 6-P has a capacity of 25,806 gallons; Tank 7-P and 8-P have a capacity of 21,446 gallons each; Tank 9-P has a capacity of 20,833 gallons; and Tank 10-P has a capacity of 10,000 gallons. Tank 11 has a capacity of 500 gallons of used oil and Storm-water Tank 1SW, with a capacity of 30,000 gallons, is located within the secondary containment in the used oil processing area. Tank 7-P has been designated for the storage of PCW. The total capacity for all used oil storage and processing tanks at the facility is 211,450 gallons. The tank system has the ability to transfer the used oil, PCW, and Industrial Wastewater to and from any of the tanks.